

REQUIRING ONE-HUNDRED AMPERE ELECTRICAL SERVICE IN ALL NEW CONSTRUCTION.

Be it ordained by the Council of the Village of Grove City, Ohio:

432701

Sec. I. No building permits shall be issued by the building inspector unless the application for the permit shows plans for the installation of one-hundred (100) ampere service, which service must be installed before a certificate of occupancy and compliance may be issued by the building inspector.

Sec. II. In complying with Sec. I of this ordinance, the following regulations must be complied with:

No single circuit shall serve more than six (6) devices or six (6) outlets; all basement outlets shall be grounded and each basement shall contain one 220 volt 3-wire outlet and one 110 volt washer outlet; all outlets less than seven (7) feet above the slab of slab type construction shall be grounded; all kitchen and bathroom outlets in all construction shall be grounded with a twenty (20) ampere capacity; one weather-proof outlet shall be located at each exterior door opening.

Sec. III. The main service panel shall be rated at one-hundred (100) ampere capacity and shall have one positive means to disconnect. The service entrance wire shall be a minimum of 2 R.H. copper wire, or its equivalent. The service panel shall contain no less than ten (10) branch circuits with accommodation for two (2) spare circuits.

Sec. IV. All wiring shall be in accordance with the National Electric Code, and the building inspector's interpretation shall govern all disputes.

Sec. V. This ordinance is hereby declared to be an emergency measure necessary for the health, safety, welfare and protection of the residents of this Village and, therefore, shall take immediate effect.

Rescinded by 1-5-60

PASSED Apr. 7-58

APPROVED _____

ATTEST W. Hysell
Clerk

W. Ernest Hysell
Mayor

W. Ernest Hysell
W. Ernest Hysell, Mayor

- | | | | | | |
|--------------------------|-------------------------------------|------------|--------------------------|-------------------------------------|---------|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | HAINES | <input type="checkbox"/> | <input checked="" type="checkbox"/> | HINTON |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | HARRINGTON | <input type="checkbox"/> | <input checked="" type="checkbox"/> | KIEHL |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | HAUGHN | <input type="checkbox"/> | <input checked="" type="checkbox"/> | WINDSOR |
| ON | YES | | ON | YES | |

George Haughn
George Haughn, President of Council

309
Memo of Ord 5-58